

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TC9964240000000764F

Dated: 03.07.2024

It is certified that an inspection team headed by NAVEEN KUMAR SURI ( SAMPLING ASSIS.) (Name of Officers with designation) from UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY inspected the DELHI PUBLIC SCHOOL PILIBHIT, GATA NO-94 P 95 AND 91P VILL- TAAH, TAHSEEL AND DISTRICT-PILIBHIT, UTTAR PRADESH on 02/07/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. LAB/BLY/2024-25/764 dated 03.07.2024 Of UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab) certified that the DELHI PUBLIC SCHOOL PILIBHIT, GATA NO-94 P 95 AND 91P VILL- TAAH, TAHSEEL AND DISTRICT-PILIBHIT, UTTAR PRADESH has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03-07-024 to 02-07-025

Signature with Seal: ..... Vipin Kumar Singh  
Name : ..... Assistant Engineer  
Designation : ..... Jal Nigam, Bareilly (R)  
Name & Address of the Office / Department : .....


To



MANAGER

DELHI PUBLIC SCHOOL PILIBHIT,  
GATA NO-94 P 95 AND 91P VILL-  
TAAH, TAHSEEL AND DISTRICT-  
PILIBHIT, UTTAR PRADESH

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Delhi Public School Pilibhit

  
Director

		Analysis Report					
		District Level Water Analysis Laboratory U.P.Jal Nigam (RURAL)					
		Near M.B.Inter Collage, Gandhi Nagar, Bareilly (U.P.)					
Customer Details							
Office Name and Address		DELHI PUBLIC SCHOOL PILIBHIT, GATA NO-94 P 95 AND 91P VILL- TAAH, TAHSEEL AND DISTRICT-PILIBHIT, UTTAR PRADESH.					
Ref Letter No & Date		0		DATE - 02.07.2024		Report No.- LAB/BLY/2024-25/764	
Basic details of sample							
District	PILIBHIT	Tehseel	PILIBHIT	Analysis Start Date	02.07.2024		
Village	TAAH	Block	-	Analysis Completion Date	03.07.2024		
Habitation	TAAH	Location	IN SCHOOL	Report Issue Date	03.07.2024		
Water Source	SUBMERSIBLE	Sample Code	PS-764	Sample Depositor	Kuldeep Singh		
Quantity of Sample	1 ltr	Date of Sample Collection	02.07.2024				
Receiving Date	02.07.2024	Sample Collector	VIJAY PAL				
Environmental Condition							
Temperature		27°C		Humidity		57%	
Technical Data of Analysis							
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7	
1	Colour	(Hazen)	0	5	15	IS 3025 (Part 4):2021	
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
4	Turbidity	(NTU)	0.85	1.00	5.00	IS 3025 (Part 10) : 2022	
5	TDS	(mg/L)	210	500	2000	IS 3025 (Part 16) : 2022	
6	PH	-	7.58	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022	
7	Iron	(mg/L)	0.2	1.00	1.00	IS:3025(Part-53):2014	
8	Sulphate	(mg/L)	13.8	200	400	IS 3025 (Part 24) : 2022	
9	Alkalinity	(mg/L)	164	200	600	IS 3025 (Part 23) : 2019	
10	Hardness	(mg/L)	160	200	600	IS 3025 (Part 21) : 2019	
11	Chloride	(mg/L)	10	250	1000	IS 3025 (Part 32) : 2019	
12	Calcium	(mg/L)	62	75	200	IS:3025(Part-40):2019	
13	Magnesium	(mg/L)	23.8	30	100	APHA 23 Edition 3500Mg Method B	
Note							
1. This Certificate refers only to the particular sample(s) submitted for testing.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.							
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.							
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.							

Page no:- 1/1


Email - anamika05anu@gmail.com  
U.P.J.N.BAREILLY (RURAL) Cont.No:- 7318253236



Prepared By  
(Anil Kumar)

अनिल कुमार  
गुणवत्ता प्रबन्धक  
जल विश्लेषण प्रयोगशाला  
उ० प्र० जल निगम बरेली (ग्रामीण)


END OF THE REPORT



Approved By  
(Anamika Singh)

अनामिका सिंह  
तकनीकी प्रबन्धक  
जल विश्लेषण प्रयोगशाला  
उ० प्र० जल निगम, बरेली (ग्रामीण)

Delhi Public School Pilibhit

  
Director